



KENYA ELECTRICITY TRANSMISSION CO.

Kawi Complex, Block B,
Popo Lane, Off Red Cross Road, South C
P. O. Box 34942 – 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

Our Ref: KETRACO/ST/044/2019

25th September, 2019

Notice to all Bidders

RE: TENDER ADDENDUM AND CLARIFICATION 2

**RE: TENDER FOR SUPPLY OF PROTECTION RELAYS FOR SUBSTATIONS-
KETRACO/PT/010/2019**

The following amendments are made to the specified provisions of tender for Supply of Protection Relays-KETRACO/PT/010/2019. Find herein the Tender Addendum and Clarifications. These documents should be returned along with the completed Form of Tender.

No.	Clarifications as requested by bidders	KETRACO Response
1.	Schedule of Requirements indicates relays from Four Manufacturers, can bidders only concentrate on the scope from a Specific Manufacture or should they bid for the whole scope of work.	Bidders shall bid for a specific scope, since a manufacturer cannot bid with a competitors' products
2.	Clarification on the full MLFB numbers for the below Siemens relays which are incomplete: 7SD5221-4AB99-5EK0-L0R 7SD5221-5CB99-7GK0 7SD5221-4AB99-5EKO 7SD522-5DB99-7CJ0	Please find the complete numbers as follows: 7SD5221-4AB99-5EK0-L0R + MOJ 7SD5221-5CB99-7GK0 +LOS+M2H 7SD5221-4AB99-5EKO -LOR-M2A 7SD5221-5DB99-7CJ0-LOR-M2H
3.	Clarification whether bidders can offer same Relay models but with recent software version with new functionalities	Since the relays are for replacement in existing station, relays should be with similar software and firmware.

PETER NJEHIA
SENIOR MANAGER, SUPPLY CHAIN