



KENYA ELECTRICITY TRANSMISSION CO. LTD.

KAWI House • Popo Rd • South C
P. O. Box 34942 – 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

Our Ref: **KETRACO/PT/017/2017/pk**

26th March, 2018

Notice to all interested bidders

RE: TENDER ADDENDUM AND CLARIFICATION 2

TENDER FOR SUPPLY OF TOOL KITS AND TEST EQUIPMENT FOR OPERATIONS AND MAINTENANCE

The following amendments are made to the specified provisions of tender for Supply of Tool Kits and Test Equipment for Operation and Maintenance. Save where expressly amended by the terms of this Clarification or previous clarifications, the Principal Tender Document shall continue to be in full force and effect.

Find herein the Tender Addendum and Clarification No. 2, consisting of one (1) page (including this page) into the copy of the Tender Documents. These documents should be returned along with the completed Form of Tender.

	Clause	Specification Requirement	Deviation/Clarification	KETRACO RESPONSE
1	Schedule of Requirements	Item No. 39 – Circuit Breaker Analyser	Shall the Circuit Breaker Analyser measure the contact resistance of the Circuit Breaker one phase at a time or the 3 phases simultaneously?	The Circuit Breaker Analyser shall have three (3) microhmeters and shall have the ability to perform simultaneous contact resistance measurements on three breaker poles at one go.

The Bid Closing date will change from Wednesday, 4th April, 2018 to **Tuesday 10th April, 2018.**

PETER NJEHIA
SENIOR MANAGER, SUPPLY CHAIN MANAGEMENT