



KENYA ELECTRICITY TRANSMISSION CO. LTD.

KAWI House • Popo Rd • South C
P. O. Box 34942 – 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

Our Ref: **KETRACO/PT/017/2017/pk**

04th April, 2018

Notice to all interested bidders

RE: TENDER ADDENDUM AND CLARIFICATION 3

TENDER FOR SUPPLY OF TOOL KITS AND TEST EQUIPMENT FOR OPERATIONS AND MAINTENANCE

The following amendments are made to the specified provisions of tender for Supply of Tool Kits and Test Equipment for Operation and Maintenance. Save where expressly amended by the terms of this Clarification or previous clarifications, the Principal Tender Document shall continue to be in full force and effect.

Find herein the Tender Addendum and Clarification No. 3, consisting of one (1) page (including this page) into the copy of the Tender Documents. These documents should be returned along with the completed Form of Tender.

| | Clause | Specification Requirement | Deviation/Clarification | KETRACO RESPONSE |
|---|--------|---------------------------|---|---|
| 1 | | Terms of Payment | Payment terms state after delivery, are letters of credit (LCs) acceptable as a mode of payment. A confirmed at Sight Irrevocable letter of credit | Letters of credit are an acceptable form of payment Not acceptable, the Letter of Credit shall not be a Confirmed at Sight |
| 2 | | Schedule of Requirements | Item 63 – Pulley Block - there is no indication of the Tonnage required. | The tonnage required is; Working Load Capacity - 2000kg Test load capacity - 3000kg Wire rope thickness - 13mm |

The Bid Closing date shall remain **Tuesday 10th April, 2018.**


PETER NJEHIA
SENIOR MANAGER, SUPPLY CHAIN