

Our Ref: KETRACO/ST/044/2019

4th September, 2019

Notice to all Bidders

RE: TENDER ADDENDUM AND CLARIFICATION 1

**RE: TENDER FOR SUPPLY OF PROTECTION RELAYS FOR SUBSTATIONS-
 KETRACO/PT/010/2019**

The following amendments are made to the specified provisions of tender for Supply of Protection Relays-KETRACO/PT/010/2019. Find herein the Tender Addendum and Clarifications. These documents should be returned along with the completed Form of Tender.

No.	KETRACO requirement Document (Page No.)	Clarifications as requested by bidders	KETRACO Response
1	Section VII: Price Schedule Pg 84	Terms of delivery: Are delivery terms Ex-Works or Delivered Duty Paid (DDP)	Delivery Duty Paid
2	Section V: Technical Specifications Pg 36 Section VIII: Form of Tender Pg 91	Scope of the contract is not clear. Is it only product Supply or Supply, installation & commissioning.	Scope is only product supply.
3	Not Indicated in Document	Kindly provide the sites where the relays are to installed & commissioned against the schedule of requirements to enable bidders consider costs implications. Will KETRACO issue separate price schedule for service	Not in scope
4	Section IV: SCC Pg 29	Payment terms: - What are the milestones for payment in the case clarification 2 is yes. Can KETRACO consider payment upon delivery of relays and thereafter payment for the services if installation & commissioning	Scope only Delivery of Products
5	Section I: Invitation to tender Pg 3 Section II: Instruction to Tenderers 2.23 Pg 14	Bid currency: Can bidders offer prices in one foreign currency. This will be a benefit to KETRACO as bidders don't have to consider hedge against the Kenya Shilling especially now the market is volatile	Bidders can offer prices in easily converted foreign currency.

6	Section V: Technical Specifications Pg 35	FAT Cost : Should the cost be included as a separate line item in the Price Schedule?	It is the bidder's responsibility to cost for the FAT which shall be included in the bid price
7	Section VI: Schedule of Requirements	Schedule of Requirements indicates relays from Four Manufacturers, can bidders only concentrate on the scope from a Specific Manufacture or should they bid for the whole scope of work.	Bidders shall bid for the whole scope, however it should be compatible with what is existing.
8	Section V: Technical Specifications Pg 35	Site Tests: The indicated site test to be specified for how many sites (in reference to clarification 3 above). Will Stability test be done for the Line Differential?	Site Tests shall not be applicable for this scope
9	Section VI: Schedule of Requirements	Clarification of the Order Code Number for Item No. 5 - ABB REL 650 -LINE DISTANCE and Item25: ABB REF 615-BACK UP (33kV)	1. REL6501MRK0085512-CB 2. REF615*HBF-FAEAGNAA1ANA1XE

PETER NJEHIA
SENIOR MANAGER, SUPPLY CHAIN