

**Our Ref: KETRACO/PT/030/2023**

**29<sup>th</sup> November 2023**

**Notice to all Bidders  
 TENDER CLARIFICATION 3**

**RE: TENDER FOR COMPLETION OF 132KV SONDU-HOMABAY-AWENDO TRANSMISSION PROJECT- TRANSMISSION LINE.**

The following amendments are made to the specified provisions of **Tender for Completion of 132 kv Sondu- Homabay-Awendo Transmission Project (Tender Number KETRACO/PT/030/2023)**. Save where expressly amended by the terms of this clarification, the Principal Tender Document shall continue to be in full force and effect.

Find herein a CLARIFICATION No. 3, consisting of three (3) pages into the Principal Tender Documents as attached. This document should be returned along with dully filled Form of Tender.

NO	CLAUSE	ITEM DESCRIPTION	CLARIFICATION REQUESTED	KETRACO RESPONSE		
1	Price schedule no 1.2, 4.2(Double circuit)	<b>Tower, Foundation &amp; Earthing.</b> All Double circuit lines are new line/items.	There is no conductor, insulators, OPGW supply and installation.	Supply and installation of conductor, insulators, OPGW for the double circuit is included in the Single circuit portion since the components are identical.		
2	Price Schedule No 1.2, Item 2	Foundation stubs and tower and Sch 4 4.2 Installation	There is discrepancy in the qty. refer below.	Maintain the quantities as in the price schedules. Any discrepancy shall be harmonised by remeasurement during implementation		
		<b>No.</b>	<b>Foundation Stubs Supply</b>		<b>Tower Supply</b>	<b>Installation</b>
		S	1		1	1
		LA	0		0	0
		MA	1	0	0	
		HA	1	1	1	
		DE	3	2	2	
		<b>Total No.</b>	<b>6</b>	<b>4</b>	<b>4</b>	
3	Price sch 1.1, item 2	Billing and pricing of stubs and additional materials	Stubs missing are to be quoted in sets.	Stubs will be billed per unit as per Price		

				schedule 1.1, item 2. But additional materials are to be billed in kilograms (Kgs)
4	Site visit	Tower earthing	In site visit it was mentioned copper should not be used and design to be done accordingly.	Confirmed for all new foundations.
5	KETRACO Clarification 2 dated 23-11-23; ITT Clause 14 & 19.5	<b>INCO-TERMS.</b> DDP, CIP and Taxes	Please clarify supply is DDP or CIP Inco-terms. Also, Sch 5 summary should reflect VAT for schedule 1	Refer to ITT clause 19.5 for applicable incoterms and ITT clause 14 for applicable taxes. Sch 1 is as per ITT 19.5 including all taxes.
6	1.4	Table 2. vehicle description. Type 2 double cabin pickup 3litre engine.	Please clarify. Employer's representative transport, in the market is 2.8 litre engine only.	Bidders to source for 3.0 Litre Engine suitable for site work and off road as specified.
7		Tower Drawing	We Request for the existing/As built Tower Drawings.	Refer to clarification list No. 2 item No. 2 & 3
8		Closing Date	Please give us 3 weeks Extension period from the submission date.	Closing date remains as per the Bid documents.

The tender closing date remains **19<sup>th</sup> December 2023 at 10.30 am. EAT.** All other terms and conditions of the tender document remains the same.

**USER REPRESENTATIVE: ENG. JUSTIN MUNA**

**DESIGNATION: PROJECT MANAGER**

SIGNATURE..... 30/11/2023

**APPROVED BY: PRISCA KUBASU**

**DESIGNATION: Ag. SENIOR MANAGER, SUPPLY CHAIN MANAGER**

SIGNATURE.....

Tender Addendum and Clarification No. 3 of Tender No. KETRACO/PT/030/2023 has been received and incorporated in the Tender Documents.

**Name of Tenderer (*in block letters*):**

---

**Signature:**

---

**Date:**

---

**Signed for the Tenderer by  
(*Name in block letters*):**

---

**In the office bearer  
capacity of:**

---

---

