

Kawi Complex, Block B,
Popo Lane, Off Red Cross Road, South C
P. O. Box 34942 - 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000

Web: www.ketraco.co.ke • email: info@ketraco.co.ke

Our Ref: KETRACO/PT/029/2024

30th September 2024

Notice to all Bidders

RE: TENDER ADDENDUM AND CLARIFICATION FOR SUPPLY OF ONE (1) 23MVA 132/33KV AND ONE (1) 23MVA 132/11KV POWER TRANSFORMERS WITH ON LOAD TAP CHANGER (OLTC) SWITCHES; TENDER NUMBER KETRACO-PT-029-2024

The following amendments are made to the specified provisions for Supply of One (1) 23MVA 132/33kv and One (1) 23MVA 132/11kv Power Transformers with On Load Tap Changer (OLTC) Switches; TENDER NUMBER KETRACO-PT-029-2024

Find herein the ADDENDUM and CLARIFICATION No. 1, consisting of THREE (3) pages into the Principal Tender Documents as attached. This document should be returned along with duly filled Form of Tender.

HESBON KISERO

Ag. SENIOR MANAGER, SUPPLY CHAIN



Kawi Complex, Block B,
Popo Lane, Off Red Cross Road, South C
P. O. Box 34942 - 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000

Web: www.ketraco.co.ke • email: info@ketraco.co.ke

TENDER FOR SUPPLY OF ONE (1) 23MVA 132/33KV AND ONE (1) 23MVA 132/11KV POWER TRANSFORMERS WITH ON LOAD TAP CHANGER (OLTC) SWITCHES; TENDER NUMBER KETRACO-PT-029-2024

NIo	Bidder's Clarifications	VETDACO: Perpense		
No	7.77	KETRACOs Response		
1	We kindly seek for an extension from	Deadline for Tender Submission		
	you for additional 14 days.	Extended to		
		29th October 2024		
2	In reference to the subject, we hereby	Deadline for Tender Submission		
	submit our request to extend the			
	above tender by three weeks from the	29th October 2024		
	closing date	i .		
3	We hereby request for an extension of	Deadline for Tender Submission		
	the closing date for the above tender	Extended to		
	by there (3) weeks.	29th October 2024		
4	The agreement does not specify the	The no-load and load losses shall be		
	specific value of no-load loss and load	capitalized for the purposes of		
	loss, please clarify, if not specified, can	comparison of the tenders. (for both		
	we consider according to the lowest	transformers)		
	cost?			
5	Please clarify whether the accessories	The accessories shall be implemented as		
	of this project group are implemented	specified in the KETRACO detailed		
	according to the domestic	specifications. (for both transformers)		
	manufacturers except for the	specifications. (for both transformers)		
	agreement has requirements?	\ '		
6	The agreement does not specify the	The connection is to a flexible conductor		
0	connection method with other			
		busbar on both HV and LV. (for both		
	equipment, please clarify whether it is	transformers)		
	implemented according to "high-			
	voltage side: soft wire overhead			
	connection, low-voltage side: hard	_		
	busbar connection".			

7 The information on environmental conditions in the agreement is insufficient, can we perform according to the following environmental conditions?

1					
	Description	Unit	Bidder's required value		
	Seismic resistance (corresponding to horizontal acceleration. Safety factor not less than 1.67)	m/s²	≤3		
	Anti-corrosion grade	/	C4		

The seismic coefficient of 0.16 G shall apply. (for both transformers)

Corrosion grade C4 shall apply. (for both transformers)