



KENYA ELECTRICITY TRANSMISSION CO.

Kawi Complex, Block B,
Popo Lane, Off Red Cross Road, South C
P. O. Box 34942 – 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

Our Ref: KETRACO/PT/028/2024

20th September 2024

Notice to all Bidders


RE: TENDER ADDENDUM AND CLARIFICATION 1

**RE: EXPRESSION OF INTEREST FOR SUPERVISION CONSULTING SERVICES
FOR NATIONAL SYSTEM CONTROL CENTRE - KETRACO/PT/028/2024**

The following amendments are made to the specified provisions of Expression of Interest For Supervision Consulting Services For National System Control Centre; Tender number **KETRACO/PT/028/2024**.


Find herein the ADDENDUM and CLARIFICATION No. 1, consisting of ONE (1) page into the Principal Tender Documents as attached. This document should be returned along with duly filled Form of Tender.

 **HESBON KISERO**
Ag. MANAGER, SUPPLY CHAIN



EXPRESSION OF INTEREST FOR SUPERVISION CONSULTING SERVICES FOR NATIONAL SYSTEM CONTROL CENTRE - KETRACO/PT/028/2024

No	Bidder's Clarifications	KETRACOs Response
1.	Electronic submission by e-mail	
2.	Electronic submission per email is accepted or a submission of hard copy is a mandatory requirement.	Hardcopy is a mandatory requirement. Bidders can use address given in the EOI.
3.	Is the OPC contract one Contract: SCADA System contractor (like GE, for example) with a Building subcontractor for the building lot, or are there two separate contracts one for the building and one for the System?	One Contract
4.	How many buildings are involved, 1 or 2 (main and backup)?	Two (Main & Back Up)
5.	If it involves the supervision of 2 buildings (main and backup), what is the distance between the two buildings?	About 100km apart
6.	What is the total built up area for each building?	Plinth areas of 5052 square meters for Main and 3360 square meters for Backup
7.	Has the OPC tender been launched? Are the System and/or construction companies known? Could we receive a copy of the building plans?	Tender launched. Final stages of the contract signing. Building plans not yet available.
8.	What is the estimated start date for the construction work?	May 2025
9.	Is Colombia an eligible country to participate in?	Eligibility issues are clear as already captured in the provided document
10	EOI format as we are unable to locate it in your website.	Consultants to submit required information in an organized manner
11	Provide a rough estimate of the budget for this particular procurement	Not available, Estimated Man Months stated in the EOI


 28/09/2024