



**KENYA ELECTRICITY TRANSMISSION CO.**

Kawi Complex, Block B,  
Popo Lane, Off Red Cross Road, South C  
P. O. Box 34942 – 00100, NAIROBI  
Phone: 020 4956000, 0719018000, 0732128000  
Web: [www.ketraco.co.ke](http://www.ketraco.co.ke) • email: [info@ketraco.co.ke](mailto:info@ketraco.co.ke)

**Our Ref: KETRACO/PT/028/2023**

**16<sup>th</sup> October, 2023**

**Notice to all Bidders.**

**RE: TENDER ADDENDUM AND CLARIFICATION 1**

**RE: TENDER FOR PROCUREMENT OF POWER VOLTAGE TRANSFORMERS  
FOR 132KV ISHIARA SWITCHING SUBSTATION (TENDER NO.  
KETRACO/PT/028/2023) TENDER CLARIFICATION 1**

The following amendments are made to the specified provisions of the tender for Procurement of Power Voltage Transformers For 132kv Ishiara Switching Substation (Tender No. KETRACO/PT/028/2023).

Find herein the Tender Addendum and Clarification No. 1, consisting of two pages. This document should be attached to the completed Form of Tender.

The Closing Date shall be 31<sup>st</sup> October 2023 at 10.30am Local time.

  
CAROLINE KYARA  
AG.SENIOR MANAGER, SUPPLY CHAIN

**TENDER FOR PROCUREMENT OF POWER VOLTAGE TRANSFORMERS FOR 132KV ISHIARA SWITCHING SUBSTATION (TENDER NO. KETRACO/PT/028/2023) TENDER CLARIFICATION 1**

No	Bidder's Clarifications	KETRACOs Response
1.	Kindly share the editable version of the Technical Specifications, GTP & TDS	Please upload from the Ariba Portal. KETRACOs procurement systems are automated, all bids are sent and received electronically.
2.	The Bidder must provide proof of supplying similar items to clients in the public/ private sector in the last 3 years. This will be in the form of LPOs, Contracts or completion certificates. Contact and email addresses on the documents should be correct for verification purposes - we request that bidders be allowed to use the manufacturers' references	Bidders can use manufacturers experience and references.
3.	We seek extension of the tender submission date by at least a week preferably the 25th of October.	The tender has been extended to close on 31 <sup>st</sup> October 2023 at 10.30am
4.	The tender name states at various titles on the documents that it is supply, installation, and commissioning of 150KVA 132/0.415kV Power VT while in the price schedule and TDS it states 50kVA, (132/ $\sqrt{3}$ )/0.240kV SF6 Insulated Power Voltage Transformer.  What is the correct technical particulars/ requirements of the Power VT?	The tender name (150KVA 132/0.415KV) refers to the combined output of (3x50kVA) Single phase Power VT units; the desired auxiliary power supply output. Power VTs are usually supplied as single units per phase hence as specified in the tender documents, the correct technical particulars/TDS is for, 50kVA, $\frac{132}{\sqrt{3}}$ / $\frac{0.415}{\sqrt{3}}$ kV Power VTs
<b>Additional Information</b>		
5.	Site Visit	There will be a site visit on Thursday 19 <sup>th</sup> October 2023. Interested bidders can visit Ishiara Substation at 10.am for familiarization of the site and scope of work.

*Handwritten signature*  
16/10/2023

*Handwritten signature*  
16/10/23