

11th May 2021

Notice to all Bidders

Ref: Expressions of Interest for Consulting Services for Supervision and Management of the EPC Construction for the pilot digital 400/132kV Makindu Substation

Tender No.: KETRACO/PT/014/2021

Sub: Tender Addendum and Clarification No. 1

The following amendments are made to the specified provisions of the above referenced tender. Save where expressly amended by the terms of this Tender Addendum and Clarification, the Principal Tender Document shall continue to be in full force and effect.

Find herein the **Tender Addendum and Clarification No. 1**, consisting of **two (2) pages**. This document should be submitted along with the completed tender documents. Tenderers must confirm acknowledgement with tender submission.



Isaac Rotich

For: Senior Manager, Supply Chain

Table 1: Tender Addendum and Clarification No. 1

No.	Clarification as requested by applicants	KETRACO Response
1	<p>I kindly ask a confirmation on whether an electronic submission of the EOI per email to the addressed indicated in the EOI notice is satisfactory or the submission of original hard copy in person or per mail is a mandatory requirement.</p> <p>We are highly interested in submitting an EOI for the above mentioned project and would be grateful for a confirmation that a submission by email until May 20th, 2021, 10:00 a.m. to the above mentioned addresses is possible.</p>	<p>The Expressions of Interest must be submitted physically in triplicate (one original and two copies) to the address below no later than 27 May 2021 at 1000 hours EAT:</p> <p>Senior Manager, Supply Chain Attn: Peter Njehia Kenya Electricity Transmission Company Limited (KETRACO) 2nd Floor, KAWI Complex, Block B Popo Road, off Red Cross Road, South C P.O Box 34942 – 00100 Nairobi, Kenya</p>
2	<p>Please clarify whether experience of implementation of Substation Automation for control and monitoring of</p>	<p>Digital substation herein refers to a substation where most of the data related to the primary power flow is</p>

	substations (DCS-Digital control system) are acceptable or Digital Substation (digitize process level in addition to Bay level and station level) is a must in submission of this EOI.	digitized immediately at the point of measurement and using a process bus for data exchange. Experience in digitisation at the bay level (process bus) is a must.
3	We request you to share the detailed TOR for better understanding of project Scope Please send us the Detailed Terms of Reference	Refer to the criteria indicated in the Expression of Interest. The detailed Terms of Reference will be shared with shortlisted applicants.

Tender Addendum and Clarification No. 1 of Tender No. KETRACO/PT/014/2021 has been received and incorporated in the Tender Documents.

Name of Tenderer (*in block letters*):

Signature:

Date:

Signed for the Tenderer by (*Name in block letters*):

In the office bearer capacity of:
