



KENYA ELECTRICITY TRANSMISSION CO.

Kawi Complex, Block B,
Popo Lane, Off Red Cross Road, South C
P. O. Box 34942 – 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

Our Ref: KETRACO/PT/029/2024

22nd October 2024

Notice to all Bidders

RE: TENDER ADDENDUM AND CLARIFICATION FOR SUPPLY OF ONE (1) 23MVA 132/33KV AND ONE (1) 23MVA 132/11KV POWER TRANSFORMERS WITH ON LOAD TAP CHANGER (OLTC) SWITCHES; TENDER NUMBER KETRACO-PT-029-2024

The following amendments are made to the specified provisions for Supply of One (1) 23MVA 132/33kv and One (1) 23MVA 132/11kv Power Transformers with On Load Tap Changer (OLTC) Switches; TENDER NUMBER KETRACO-PT-029-2024

Find herein the ADDENDUM and CLARIFICATION No. 3, consisting of TWO (2) pages into the Principal Tender Documents as attached. This document should be returned along with duly filled Form of Tender.

HESBON KISERO
Ag. SENIOR MANAGER, SUPPLY CHAIN



KENYA ELECTRICITY TRANSMISSION CO.

Kawi Complex, Block B,
Popo Lane, Off Red Cross Road, South C
P. O. Box 34942 – 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

**TENDER FOR SUPPLY OF ONE (1) 23MVA 132/33KV AND ONE (1) 23MVA 132/11KV
POWER TRANSFORMERS WITH ON LOAD TAP CHANGER (OLTC) SWITCHES; TENDER
NUMBER KETRACO-PT-029-2024**

No	Bidder's Clarifications	KETRACOs Response
1	Kindly provide us with detailed list of equipment and accessories for which bidder must provide drawings and catalogs to ensure compliance with evaluation criteria.	HV, LV and neutral bushings, conservator, radiators, valves, oil and gas actuated relays (such as pressure relive device, buchholz relay, oil surge relay), oil level gauges, temperature gauges, cooling systems, tap changer (OLTC), dehydrating breathers, bushing current transformers,
2	For Tenderers 40% Rule: The whole transformer is manufactured and tested at factory as such it is impossible to meet this requirement. Kindly delete the same.	Bidders are requested to indicate in the form if they are importing the transformers and will not meet the 40% threshold.
3	Clarification on whether the Tender security to be issued is limited to only Bank guarantee or we can also issue one from Insurance company.	Tender security shall be in the form of (a) a bank guarantee; (b) a guarantee by an insurance company registered and licensed by the Insurance Regulatory Authority (c) A guarantee issued by a financial institution approved and licensed by the Central Bank of Kenya.
4	Please state the validity period of the tender security.	Validity period is 120 days
5	Kindly confirm on the completion period of this project.	9 months